

SHREE RAM TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001 : 2015 Approved Laboratory

Lab: A-2/103, Site-V, UPSIDC Industrial Area, Kasna, Greater Noida-201306

H.O. 223, 2nd Floor, Living Style Mall, Jasola, New Delhi-110025

Mob: 9953984801, 9717160780, 9999024801, E-mail: sl.noida@gmail.com

E-mail: info@shreeramlab.com, shreeramlab@yahoo.com, Website: www.shreeramlab.in

Complete Analytical Solution
ISO 14001 : 2015 & ISO 9001 : 2015 Certified

TEST REPORT

Issued to : M/S BLS world School HS-03, Sector- 16, Greater Noida West Uttar Pradesh	Report No.	W-040522-01
	Report date:	06/05/2022
	Sample Received:	04/05/2022
	Analysis date:	04/05/2022 to 06/05/2022
	Sampled By:	Customer

Sample Description: R.O. Water

P- 1/1

Condition of Sample: Received in Sealed & Marked Plastic Bottle.

RESULT

Drinking Water–Essential Tests as per IS 10500:2012

S.No.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
1.	Odour	IS:3025(P-5) 2018	Unobjectionable	Unobjectionable
2.	Taste	IS:3025(P-8) 1984 (Reaffirmed- 2017)	Agreeable	Agreeable
3.	Colour (Hazen)	IS:3025(P-4) 2021	< 1.0	5 max
4.	Turbidity (NTU)	IS:3025(P-10) 1984 (Reaffirmed- 2017)	Nil	1 max
5.	pH value (at 25 °C)	IS:3025(P-11) 1983 (Reaffirmed- 2017)	7.12	6.5 to 8.5
6.	Total Dissolved solids (mg/l)	IS:3025(P-16) 1984 (Reaffirmed- 2017)	392	500 max
7.	Total Hardness (as CaCO ₃) (mg/l)	IS 3025 P-21:2009 (Reaffirmed- 2019)	196	200 max
8.	Chloride (as Cl) (mg/l)	IS:3025(P-32) 1988 (Reaffirmed- 2019)	28.71	250 max
9.	Iron (as Fe) (mg/l)	IS:3025(P-53) 2003 (Reaffirmed- 2019)	0.0286	0.3 max
10.	Residual Free Chlorine(mg/l)	IS:3025(P-26) 2021	Nil	0.20 max
11.	Fluoride (as F) (mg/l)	APHA 4500 (D)	0.0019	1.0 max
12.	MICROBIOLOGICAL PARAMETERS			
i	Coliform (per 100ml)	IS 1622:1981 (Reaffirmed- 2019)	Absent	0 max
ii	E. Coli (per 100ml)	IS 1622:1981 (Reaffirmed-2019)	Absent	0 max

Remark: The Tested Parameters meet as per BIS specification.


END OF REPORT

TESTED BY




Sushma Punia

SUSHMA PUNIA
PRINCIPAL
BLS WORLD SCHOOL
GREATER NOIDA WEST-201009



Note:- (1) The above results are related only to the test performed on the sample, Endorsement to product is neither inferred. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in any advertising media without special permission in writing (3) Sample will be destroyed after 30 days from the date of reporting unless otherwise specified.

(4) Total liability of our lab is limited to the invoice amount (5) report refers to the sample drawn by shree ram testing Laboratories unless mentioned otherwise



GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY
Plot No.01, Sector Knowledge Park-IV, Greater Noida
Distt.- Gautam Budh Nagar (UP)

Ref.: H.D./2022/ 510

Date: 04/05/2022

SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by under signed from **Health Department, GNIDA** inspected **BLS World School**, HS-3, Sector-16, Greater Noida (West), Distt- G.B. Nagar (U.P.) premises has been found satisfactory during the inspection. You are requested to ensure the above conditions throughout the session as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of **One Year**.

Senior Manager (Health)

To,

Principal
BLS World School
HS-3, Sector-16
Greater Noida (West)
Distt-G.B. Nagar (U.P.)

SUSHMA PUNIA
PRINCIPAL
BLS WORLD SCHOOL
GREATER NOIDA WEST-201009